Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2017	1/23/17	3	5	25	Wind	99.99995%
	2/18/17	3	4	120	Equipment damage	99.99968%
February 2017	2/20/17	3	5	60	Electrical failure	
	3/10/17	1	3	30	Squirrel	99.99981%
March 2017	3/11/17	1	2	60	Squirrel	
	3/17/17	3	1	120	Equipment damage	
	4/14/17	1	3	60	Squirrel	99.99970%
April 2017	4/20/17	1	3	50	Equipment worn out	
	4/27/17	3	3	120	Equipment Damage	
	4/30/17	3	2	60	Equipment Damage	
May 2017	5/2/17	2	5	30	Equipment Damage	99.99982%
	5/17/17	2	1	45	Equipment Damage	
	5/17/17	2	4	45	Equipment worn out	
	5/19/17	2	1	45	Equipment Damage	
	5/23/17	1	5	15	Squirrel	
June 2017	6/6/17	1	3	30	Squirrel	99.99939%
	6/7/17	3	12	90	Human Accident	
	6/15/17	1	5	60	Tree	
	6/15/17	3	6	15	Bird	
	6/16/175/23/17	3	1	60	Tree	



